



Service Request #	924824
Inspection Report #	4146879

Inspection Address:	Reference Number(s):	Inspection Completion Date: JAN 04, 2013
	Facility Type: OPEN TO PUBLIC OFFICE	Item Type: Passenger Elevator
Customer Name and Address:	Task Type: ED-Periodic Inspection	<p>The facility/equipment is inspected in accordance with Ontario's Technical Standards & Safety Act and the appropriate regulations and codes. When an Inspector's order is issued, time limits for compliance reflect the severity of the violation and serve to avoid disruption of service.</p>

Line	Reference and Order(s)	Compliance Date
62441 1-1	The two way in car communication means shall be made operative in accordance with 2.27.1 of B44-00 U1-02.	FEB 04, 2013

Standard Notes

Where an inspector performs a follow up inspection and finds that the order(s) have not been completed, the owner (for periodic inspection issues) or the contractor (for minor alteration issues) will be billed at three times the regular charge for inspection. The order(s) will remain outstanding and will be subject to an additional follow up inspection. A regular inspection includes half hour travel time per site plus actual inspection time. There is a minimum billable time of one hour per site.

Failure to comply with inspection orders by the required date shall result in this device being removed from service.

Labour Detail

Date	Activity	Hours	Comments
JAN 04, 2013	Inspection	1	

Other Charges Detail

Date	Activity	Qty	Comments
JAN 04, 2013	Travel	1	

Customer Signature & Position / Date:		Inspector Name: Crane, John	Inspector Contact Number: 647-459-9673
Report Received By:	Customer Contact Number:	Inspector Email: jcrane@tssa.org	Inspector Fax:

As a not-for-profit regulatory authority, TSSA operates on a cost recovery basis. An Invoice will be issued for the Total Charges Incurred.
(Note: This is not an invoice)